

**निर्माता अनुमोदन / MANUFACTURER APPROVAL**

संदर्भ: CC/QA&amp;I/2023/Letter/399

दिनांक: 09 OCT 2023

|   |  |                |                      |
|---|--|----------------|----------------------|
| प्रस्तावकर्ता का नाम/ Name of Proposer      | M/s GE T&D India Limited, Padappai   |                |                      |
| निर्माता का नाम/ Name of Manufacturer       | M/s MDM Engineering and Technologies (Unit-II)   |                |                      |
| सी.आई.एन संख्या/ CIN Number                 | NA   |                |                      |
| निर्माता का पता/ Address of Manufacturer    | Door No. / Plot No.: 17/3b4, 8/5b, Avadi Road, Senerkuppam, Dist. Thiruvallur (Tamil Nadu) |                |                      |
|   | City: Thiruvallur  | Country: India | Pin/Zip Code: 600056 |
| निर्माता कोड/ Manufacturer Code             | 3000001724   |                |                      |
| नाम और संपर्क विवरण/ Name & Contact details | Shri Baskar D<br>+91-9840184858   sales@mdmtech.in   |                |                      |
| मद का नाम/ Item Name                        | Bus Duct enclosure up to 800 kV GIS  |                |                      |
| संचार संदर्भ/ Communication Reference       | 10008  |                |                      |
| वैधता अवधि/ Validity period up to           | 06 October 2024  |                |                      |

**Background details:** M/s GE T&D India Limited, Padappai had requested for sub-vendor approval of M/s MDM for supply of Bus Duct enclosure up to 800 kV GIS. Based on review of submitted documents and assessment of M/s MDM, we agree to the proposal of M/s GE for approval of M/s MDM, Thiruvallur for supplying these items to POWERGRID projects.

Manufacturer/ Contractor shall be fully responsible for satisfactory performance of approved products. Please note that the items supplied shall meet the requirements of POWERGRID Specifications/ Approved Drawing/ DRS/ Data Sheets/ GTP/ MQP/ FAT Procedure, relevant IEC/IS standards and project specific type tests. The manufacturer shall ensure that the above documents are available at the works so that proper inspection is carried out without delay. If, at any point of time, any abnormality is noticed in this regard, we reserve the right to increase our involvement by way of additional inspection and/or additional customer inspection points (CIP) at any stage or withdraw this approval with immediate effect. Please note that further approval shall be considered based upon performance, quality, and supplies during this approval period. Manufacturer shall ensure that request for renewal of above approval should come at least 1 month before expiry of this approval letter.

**Special Remarks:**

- Welders approval to be obtained in line with POWERGRID guidelines prior to commencement of manufacturing for POWERGRID orders.
- M/s MDM will have to successfully demonstrate the manufacturing processes including lifting, moving of pipes and routine testing (hydraulic, Helium leak test) for first lot of Bus duct enclosure for 800kV GIS to POWERGRID.
- M/s MDM is required to submit compliance of below observations for improvement before applying for next renewal.
  - Any energy efficiency measures (green initiatives) such as use of energy efficient equipments, paper recycling etc. may be adopted.
  - Store documentation process is done manually in register. M/s MDM is advised to use productivity tools such as Inventory management software for store, Software for Billing, Invoicing, Dispatch, Barcoding for traceability and proper record keeping.
  - Open Storage facility for Pipes to be improved for identification of raw material and Indoor storage space to be identified & demarcated for finished goods.

भारतीय सरकार  
09/10/23

- Customer complaint register to be opened and records to be maintained.
- Manufacturer to ensure adherence to the POWERGRID guidelines for Welder qualifications.

Note 1: "The ministry of MSME has launched the "Financial Support to MSMEs in ZED certification scheme" for benefit of MSMEs. MSMEs are requested to avail maximum benefits under the scheme. For more details on ZED, you may please visit this link- (<https://zed.org.in/>)." )"

Note 2: Letter regarding- Non-Indulgence in Fraudulent / Unethical Practices enclosed.

आशिश कुमार सखना  
09/10/23

(ASHISH KUMAR SAXENA)

उप महाप्रबंधक (गु° आ° एवं नि°)

प्रति: सम्बंधित निरीक्षण कार्यालय

Enclosure: As above